

ACCEPTING BIDS

The City of Vidalia will be accepting sealed bids for the installation of a deep well for irrigation at the Warmouth Sands Golf project.

Warmouth Sands Golf Course Well specifications:

- * Drilling one 6" Limestone Deep Well EPD approved for irrigation of golf course with 6" .188 wall black steel casing
- * 40 hp Franklin electric motor, 3 phase, 460V
- * 40 hp Franklin electric pump end open flow
- * 40 hp Starter panel
- * 4" steel drop pipe
- * #6 Heavy duty pump cable
- * 6" x 4" well seal
- * 4" steel tee
- * 4" steel plug

Water and Pressure requirements:

- * 400 GPM @ 0 PSI

For more information, or any questions, please contact City Manager Bill Bedingfield at 912-537-7661. Bids may be mailed to the address below, but must be received by February 28, 2024 at 2:00 p.m. Bids may hand-delivered and must be sealed with vendor name, address, telephone number, and clearly marked "Deep Well". No emailed or faxed bids will be accepted.

**William E. Bedingfield, City Manager
City of Vidalia
302 E First Street, Suite C
Vidalia, GA 30474
Email: BBedingfield@vidaliaga.gov**